

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-0078:182 Page 1 of 1

**CATEGORY:** Misc. Device/Control Unit Accessories

**LISTEE:** ADEMCO, 165 Eileen Way, Syosset NY 11791  
Contact: Harry Pashkoff (516) 921-6704 EXT 3056 FAX (516) 364-6953

**DESIGN:** Model 4208U eight-zone remote point module and Models \*4208SN and 4208SNF eight-zone remote point module/Class A interface. Units are optional devices for use with listee's separately listed control units. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 4208U: 12 VDC, 28mA  
4208SNF: 10-14 VDC, 22 or 33 mA  
\*4208SN:

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as control unit accessories for use only with Ademco's separately listed compatible fire alarm control units.

\*Rev. 12-15-2002 IPI



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **DECEMBER 15, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager